



FICHA TECNICA VISOR IS/51

Propietario del programa: AAA

Margen de error = ± 3 dB

Cliente:

Resultado de la verificacion:

Visor Acustico IS/51

Informe N°:

Fecha:

Local:



$R_w = 54$ dB

100 - 3150

C -1

Ctr -5

$R_A = 53$ dB

Frecuencia	dB
50	20,1
63	24,8
80	29,6
100	33,7
125	37,1
160	40,1
200	42,9
250	45,3
315	47,7
400	50
500	52,2
630	53,9
800	55,4
1000	56,5
1250	56,8
1600	54,3
2000	60,7
2500	65,6
3150	70,3
4000	74,7
5000	79,1
Rw	54
C	-1
Ctr	-5

