



FICHA TECNICA VISOR ACUSTICO IS/60

Propietario del programa: AAA
Margen de error = ± 3 dB
Cliente:
Resultado de la verificacion:

Visor Acustico IS/60
Informe N°:
Fecha:
Local:



R_w = 61 dB

100 - 3150
C -1
Ctr -3

R_A = 60 dB(A)

Frecuencia	dB
50	30,1
63	38
80	46,4
100	48,7
125	50,5
160	52
200	53,4
250	54,8
315	56,2
400	57,6
500	58,9
630	60,1
800	58,9
1000	58,7
1250	57,7
1600	57,5
2000	67
2500	68,7
3150	70,5
4000	72,3
5000	74,1
R_w	61
C	-1
Ctr	-3

